

## [EXT]Environmental Impact Report for Diablo Canyon

McLean, Kevin@CALFIRE <Kevin.McLean@fire.ca.gov>

Mon 9/25/2023 1:33 PM

To: PL\_Diablo <PL\_Diablo@co.slo.ca.us>; Susan Strachan <sstrachan@co.slo.ca.us>; Cindy A. Chambers <cchambers@co.slo.ca.us>

Cc: josh.taylor\_fire.ca.gov <josh.taylor@fire.ca.gov>; Veyna, Garrett@CALFIRE <Garrett.Veyna@fire.ca.gov>

**ATTENTION:** This email originated from outside the County's network. Use caution when opening attachments or links.

Listed below are the comments from the SLO County Fire Marshal's Office in regards to the Environmental Impact Report for Diablo Canyon.

1. 4-14-16, Any blockage of Avila Beach Drive will require prior coordination with County Fire to provide adequate fire protection for the Avila Beach Community.
2. General comment in regards to the decommissioning: The determination for hot works during decommissioning construction will be determined during the permitting process with County Planning and Building forwarding the Plans to County Fire.
3. 17-10 Wildfire: SRA regulations were updated and adopted in April 2023. They are now called State Minimum Fire Regulations. Officially known as Title 14 of the California Code of Regulations (14CCR), Division 1.5, Chapter 7 Subchapter 2, Articles 1-5. Additionally, any application for a building permit for new construction not relating to an existing structure or application for a use permit will need to follow these regulations included but not limited to the Dead-end Road standard. (14CCR, 1270.03)
4. 7.17-17: to clarify, C.C.R. Title 14 only comments on the allowable distance for dead end roads. San Luis Obispo County secondary egress / access reference standard, which has been updated in 2023, gives the occupancy limit. Additionally, San Luis Obispo County Fire did not adopt appendix D of the California 2022 Fire Code. However, Section 503.1.2.1.1 of the San Luis Obispo County Title 16 states new developments of dwellings units, where the number of dwelling units exceeds 30, shall be provided with two separate and approved fire apparatus access roads when located in a state responsibility area or a very high fire hazard severity zone
5. General Comment- Any motor, engine, boiler, stationary equipment, welding equipment, cutting torches, tarpots, or grinding devices from which a spark, fire, or flame may originate, which is located on or near any forest-covered land, brush-covered land, or grass-covered land, shall conform to the requirements of Public Resource Code.



### Kevin McLean

Battalion Chief – Fire Marshal

1150 Laurel Lane Ste. 175

San Luis Obispo, CA 93401

805-593-3422 Office



